



NOTES:-

- MAXIMUM HEIGHT AT WHICH METERS CAN BE FITTED IS 1.7 METERS TO TOP OF METER FROM FINISHED FLOOR LEVEL.
- MINIMUM HEIGHT AT WHICH METERS CAN BE FITTED IS 300mm FROM BOTTOM OF METER TO FINISHED FLOOR LEVEL
- MINIMUM SIZE OF TRUNKING IS 150mm X 150mm
- ADDITIONAL SWITCH FUSES NOT SHOWN FOR MULTIPLE TARIFFS.
- THE AREA OF TRUNKING DIRECTLY ABOVE J.E. MAIN DISTRIBUTION BOARD IS FOR METER TAILS ONLY. NO OTHER CABLES ARE PERMITTED TO PASS THROUGH THIS AREA (AREA SHOWN HATCHED ABOVE)
- IT IS USUALLY A CONDITION OF OUR SERVICE QUOTATION FOR MULTI-WAY INTAKES THAT THE ELECTRICAL CONTRACTOR SUBMITS A SCALED SKETCH OF THE PROPOSED EQUIPMENT LAYOUT FOR OUR APPROVAL BEFORE WORK COMMENCES ON SITE.

SPACING BASIS:-

Spacing based on Meter = 140mm Wide x 180mm Tall
 Single Phase Sw. Fuse = 300mm Wide x 360mm Tall
 Spacing Between Meters / Sw. Fuses / Trunking = 25mm
 Spacing for three phase meters would need to be increased to allow for 171mm wide x 285mm tall meters

Scale= 1:20 @ A3

Rev	Date	Description	Drn	Appd
B	22-10-12	Title and trunking spacing changed	TSB	TB
A	17-09-12	Modifications by TB	TSB	TB
-	21-07-11	Redrawn in CAD	TSB	TB

Project

Front Elevation

Title

**Typical Layout of
Metering Intake for
Centrally Positioned
10 Way Distribution Board**

The Intellectual Property Rights (IPR) i.e. Patents, Copyright, Trade Secrets, Design Rights etc., remain strictly the property of 'Jersey Electricity Company plc' and may not be copied and /or reproduced in any form without their 'Express Permission'.



Jersey Electricity plc

The Powerhouse PO Box 45 Queen's Road St. Helier Jersey JE4 8NY.
 Tel - 01534 505000 Fax - 01534 505011 e-mail - jec@jec.co.uk

Drng. No. **440-N21-1**

Revision **B**