



NOTES

- Any proposed alteration to the layout of the cut-out and metering arrangements to be agreed with Jersey Electricity PLC. Before installation.
- See Jersey Electricity PLC. Drawing no. 35-R21 for cupboard construction details.
- Meter cabinet hinges on left hand side.
- The applicant must make provision for coax cable to be run from the service position to the exterior of the building at a location where a discreet GPRS aerial can be mounted should there be insufficient signal strength at the service position.
- The new supply position must be electrically safe and environmentally secure. JE plant and equipment shall only be fixed directly onto a visible 16mm marine ply backboard. The applicant's contractor shall ensure the backboard is adequately fixed to any substrate layers. It being understood that this will not be to the detriment of the enclosure's fire rating in compliance with the relevant building byelaws.

|   |            |   |     |     |
|---|------------|---|-----|-----|
| K | 08-12-2023 | Dimensions Altered                                  | AB  | HM  |
| J | 20-11-2023 | Minimum distance to obstruction updated             | TSB | ML  |
| H | 25-08-23   | Fused switch moved to right hand side               | TSB | ML  |
| G | 02-09-22   | Added notes 4 & 5 and Mounted board annotation      | AB  | TJB |
| F | 11-05-21   | 150min dimension removed and 500 added from service | TB  | ML  |
| E | 15-09-11   | Dimensions Added to Bottom of Board                 | TB  | AM  |
| D | 22-08-11   | New Lucy Switchgear Added                           | TB  | AM  |
| C | 01-04-10   | Non Standard 300a E20 added                         | TB  | DP  |
| B | 06-05-09   | Cyclo E20 and Kw Meter E20 added                    | TB  |     |
| A | 20-11-06   | Depth of mains switch added                         | AD  |     |

| Rev | Date | Description | Dwn | App |
|-----|------|-------------|-----|-----|
|-----|------|-------------|-----|-----|

The Intellectual Property Rights (IPR) in Patents, Copyright, Trade Secrets, Design Rights etc., remain strictly the property of 'The Jersey Electricity Company Ltd.' and may not be copied and /or reproduced in any form without their 'Express Permission'.



Jersey Electricity plc

The Powerhouse PO Box 45 Queen's Road St. Helier Jersey JE4 8NY.  
Tel - 01534 505460 Fax - 01534 505565 e-mail - jec@jec.co.uk

Project

Energy Division

Title  
General Arrangement Of Metering  
For 300A/400A Industrial Service  
With Reduced Height

|                 |                 |             |          |
|-----------------|-----------------|-------------|----------|
| Scale<br>N.T.S. | Date<br>21-7-11 | Drawn<br>TB | Approved |
|-----------------|-----------------|-------------|----------|

|                       |               |
|-----------------------|---------------|
| Dwg. No.<br>205-N21-6 | Revision<br>K |
|-----------------------|---------------|