



NOTES

- Cupboard to be installed onto wall according to manufacturer's instructions and required dimensions
- Door frame to provide a rain proof seal
- Approved lock to be fitted
- Backboard to be in good condition and may be encased in a layer of GRP
- Duct to be installed as indicated flush inside the bottom of the box
- All internal cabling to enter at bottom of the box away from the location of Jersey Electricity equipment
- All access holes to be cut neatly with hole saw, or 'knock-out' used
- Ownership and maintenance is the responsibility of the householder
- The cupboard may be painted to match other features
- Maximum permissible length of cabling (meter tails) From JE meter to Customers equipment is 3 metres
- Dimensions vary according to cabinet type (Rosden/Normans/Pentagon)
- Meter cupboard with internal dimensions less than: H: 650mm W: 480mm D: 150mm may not be suitable for Comfort Heat, Economy 7 or Economy 20 tariffs.

NOTE. All dimensions in millimetres

Rev	Date	Description	Drn	Appd
B	26-02-2013	700mm dimension added	TSB	EP
A	01-10-2012	Customer ducts added	TSB	EP
-	24-01-2011	Original Issue	TSB	-

<p>Title</p> <p>Typical Method of Installation of Single Phase Surface Meter Cupboards.</p>				
<p>The Intellectual Property Rights (IPR) i.e. Patents, Copyright, Trade Secrets, Design Rights etc., remain strictly the property of Jersey Electricity Company plc and may not be copied and /or reproduced in any form without their 'Express Permission'.</p>				



Jersey Electricity plc

The Powerhouse PO Box 45 Queen's Road St. Helier Jersey JE4 8NY
Tel - 01534 505000 Fax - 01534 505011 e-mail - jec@jec.co.uk

<p>Drng. No. 211-N21-2</p>	<p>Revision B</p>
-----------------------------------	--------------------------