



145


65 Slot size 110 x 30 20mm wall to centre of slot




Sprint 215 three phase meter general / (E7/CH/E20/E20+)



Elster A1700 CT/HV meter





Allow 30mm clearance above meter and 20mm clerance on each side of meter

Grommet strip to be used on all metal trunking installations

Advised slot sizes are measured from the wall.

All cables must be run through same slot

NB All measurements in millimeters NTS

₽	15-04-2019	Notes Amended	TSB	NS
С	13-03-2019	Meters Resized	TSB	NS
В	21-05-2015	Meters removed	TSB	DP
Α	15-1-2004	Diagram revised	AD	
	4-7-2003	Original Issue	AD	
Rev	Date	Description	Drn	Appd

STANDARD METER SIZES



 Powerhouse
 PO
 Box
 45
 Queen's Road
 St. Heller
 Jersey
 JE4
 8NY

 Tell- 01534
 505000
 Fax - 01534
 505011
 e-mall- jec@jec.co.uk

The Intellectual Property Rights (IPR) ie Patents, Copyright, Trade Secrets, Design Rights etc... remain strictly the property of 'Jersey Electricity Company plc' and may not be copied and /or reproduced in any form without their 'Express Permission'.

80-N21

D