



Single Phase Metering - Taken from BS7671 Table 4D1A

Cable Size	Installation Method		JE Service Fuse
	Clipped direct with DI cable	In Trunking with single insulated cable	
16	YES	YES	60
16	YES	NO	80
25	YES	YES	100

Rev	Date	Description	Dwn	Appd
A	05-11-2012	Table added and modifications	TSB	MV
-	20-08-2012	Original Issue	TSB	MV

Notes

***IF THE CONSUMER UNITS ARE WITHIN 3m OF THE METER THEN NO ISOLATION IS REQUIRED PRIOR TO THE CONSUMER UNIT MAIN SWITCH.**

CABLE SIZE IS DEPENDANT ON THE SERVICE LOADING AS SPECIFIED BY THE ESE FORM AND THE SERVICE FUSE SIZE. SEE INSET TABLE

Title

TYPICAL SMART METER OR PAYG SINGLE PHASE GENERAL DOMESTIC OR E7 RATE CHANGE ONLY INSTALLATION

The Intellectual Property Rights (IPR) i.e. Patents, Copyright, Trade Secrets, Design Rights etc., remain strictly the property of 'Jersey Electricity Company plc' and may not be copied and /or reproduced in any form without their 'Express Permission'.



Jersey Electricity plc

The Powerhouse PO Box 45 Queen's Road St. Helier Jersey JE4 8NY
Tel - 01534 505460 Fax - 01534 505565 e-mail - jec@jec.co.uk

Drg. No.

484-N21

Revision

A