



Applicable Tarrifs (Import Meter)	
General (Domestic & Commercial)	YES
Comfort Heating	NO
Economy 7 (Load Switching)	NO
Economy 7 (Rate Switching)	YES
Economy 20	NO
Economy 20+	NO

Notes

- If the consumer unit is visible and within 3m of JE equipment, no additional point of isolation is required before the consumer unit main switch.
- Additional point of isolation, where required, can be a main linked switch, linked circuit-breaker, or linked switch-fuse. Both line and neutral conductors need to be switched.
- Earthing not depicted.
- Export meter will be on the Green Export Guarantee tariff.
- All meter tails are to be provided by the relevant contractor.

Title

TYPICAL ARRANGEMENT  
FOR SINGLE PHASE EXPORT  
METER INSTALLATION ON  
SINGLE PHASE, SINGLE  
ELEMENT SERVICE

The Intellectual Property Rights (IPR) ie. Patents, Copyright, Trade Secrets, Design Rights etc., remain strictly the property of 'Jersey Electricity Company plc' and may not be copied and /or reproduced in any form without their 'Express Permission'.



The Powerhouse PO Box 45 Queen's Road St. Helier Jersey JE4 8NY  
Tel – 01534 505460 Fax – 01534 505565 e-mail – jec@jec.co.uk

Drg. No. 223-N21-3

Revision E

Rev	Date	Description	Drn	Appd
E	17-06-2025	Minor Simplifications	AB	CM
D	13-08-2024	Minor Changes Made	EY	NS
C	25-07-2024	Main Fuse lined up with meter and meters reduced	TSB	NS
B	21-10-2020	Minor Changes Made	EY	NS
A	2-2-2017	Minor Changes and Text Added	EY	RM
-	9-4-2008	Original Issue	AD	